

Pipe Hangers

Pipe hangers are used to support a sprinkler piping system from the building structure. Two or more listed components may be required to form a complete hanger. The specific components required depend upon the type of building construction and the pipe size.

Pipe Hangers

Product Designation	Hanger Rod Size, m m,	Component Description	For Nominal Pipe Sizes, m m
AB	9.5	Beam C-Clamp	20 through 100 mm
AB	10	"	20 through 100 mm
TKN-10*	10	"	20 through 100 mm
TK-12	12	"Beam Clamp"	20 through 200 mm
TK16 M10	10	"Beam Clamp"	20 through 100 mm
TK16 O 11	10	"Beam Clamp"	20 through 100 mm
TK16 3/8"	3/8 in.	"Beam Clamp"	3/4 through 4 in.
TK16 M12	12	"Beam Clamp"	20 through 200 mm
TK16O 13	12	"Beam Clamp"	20 through 200 mm
TK16 1/2"	1/2 in.	"Beam Clamp"	3/4 through 8 in.
TK16 M16	16	"Beam Clamp"	20 through 300 mm**
TK16O 17	16	"Beam Clamp"	20 through 300 mm**
TK16 5/8"	5/8 in.	"Beam Clamp"	3/4 through 12 in.**

*For European jurisdictions that prefer to use clearance holes for the threaded rod and hex jam nuts to secure the rods to the beam clamp.

**Approved for use with the set screw on the load side.

Company Name:	VS Guss AG
Company Address:	Parallelstrasse 17, D-42719 Solingen, Germany
Company Website:	http://www.vsguss.de
New/Updated Product Listing:	No
Listing Country:	Germany
Certification Type:	FM Approved